

**BROOKHAVEN NATIONAL LABORATORY
MEMORANDUM**



Date: January 22, 1999
To: Distribution
From: Roy Heyder
Subject: Minutes - ASSC PASS subcommittee Jan, 8 , 1999 re: 1008 and Peer 19 state table review

Members Present: A. Etkin, R. Frankel, R. Heyder, T. Robinson, P. Ingrassia, A. Mc geary, P. Gionotti, W. Mackay, D. Beavis

Action Items

RHIC: A) New 99-RC-1 1GI1 entry key shall be changed to RHIC sweep key (#15).

Review of Peer 19 state table

1. The row for P1 command fans off in the compressor and refrigerator was removed.
2. Rows were added for each of the compressor room thermostats to control the fans.
3. Rows were added for Ngfan rio.

Review of 1008 state table

1. The ODH sensors were considered not necessary and are being removed from the state table.
2. A row for experimental fan on/off was added to pg 2.